

14,816

FILED FOR RECORD
at 11:50 o'clock a M



SEP 26 2017

JENNIFER LINDENZWEIG
County Clerk, Hunt County, TX
By *J. Lindenzweig*

September 14, 2017

Office of Hunt County Judge
The Honorable John Horn
Hunt County Courthouse
2507 Lee St. Room 107
Greenville, Texas 75401

Farmers Electric Cooperative Member: George Gray
Service Order Number: 1607003521

Dear Judge Horn,

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities across Hunt County Road 2508 which is located, 3250' southeast of County Road 2506 in Hunt County, Texas. Site location map is enclosed. The construction sketch has not been drafted at this time. All road crossing will have a minimum vertical clearance of 22 feet.

We would also like to request approval to **remove the trees along the county's right of way** on the north said of CR 2506 and east side of CR 2506 as indicated on the attached map.

If you have any questions, please contact Patrick Covington office, 903-453-0565 or cell, 903-513-1331.

Sincerely,

Patrick Covington

Patrick Covington
Engineering Assistant
pcovington@farmerselectric.coop
Phone 903-453-0565
Mobile 903-513-1331

Submitted by Brandon Darrow
Field Engineering Coordinator

Enclosures



14,816

Farmers Electric Cooperative

A Touchstone Energy Cooperative

2000 I-30 E
Greenville, TX 75402

301 N. Hillcrest
Sulphur Springs, TX 75482

FILED FOR RECORD
at 11:50 o'clock a M

SEP 26 2017

JENNIFER LINDENZWEIG
County Clerk, Hunt County, TX
By *J. Lindenzweig*

108 W. Marble
Wylie, TX 75098

September 12, 2017

Office of Hunt County Judge
The Honorable John Horn
Hunt County Courthouse
2507 Lee St Room 107
Greenville, TX 75401

Farmers Electric Cooperative Member: Texas Diamond Custom Homes
Service Order Number: 1709002358

Dear Judge Wood,

Farmers Electric Cooperative, Inc. is requesting permission to re-route existing electrical power distribution facilities across CR 2560, which is located approximately 678 feet north of Private Road 2558 located in Hunt County.

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossing will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact your field engineering representative Griffin Trommer at 903-513-9152 mobile.

Please send approval back to our engineering group at: engcoordinators@farmerselectric.coop

Sincerely,

Griffin Trommer
Engineering Assistant

Enclosures

Submitted by:
Tricia Griffin
Field Engineering Coordinator
Office: 903-453-0563 Fax: 903-453-0663
tgriffin@farmerselectric.coop

Approved Denied

Date: _____

County Comments: _____
