




Farmers Electric Cooperative

A Touchstone Energy[®] Cooperative 

2000 I-30 E
Greenville, TX 75402

301 N. Hillcrest
Sulphur Springs, TX 75482

14,976

FILED FOR RECORD
at 11:59 o'clock 2 M

FEB 13 2018

JENNIFER LINDENZWEIG
Clerk, Hunt County, TX
By *J. Lindenzweig*

108 W. Marble
Wylie, TX 75098

January 15, 2018

Office of Hunt County Judge
The Honorable John Horn
Hunt County Courthouse
2507 Lee St Room 107
Greenville, TX 75401

Farmers Electric Cooperative Member: Michael Swan
Service Order Number: 1801002392

Dear Judge Wood,

Farmers Electric Cooperative, Inc. is requesting permission to re-route existing electrical power distribution facilities across County Road 2522, which is located approximately .3 miles east of FM 1565 located in Hunt County.

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossing will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact your field engineering representative Griffin Trommer at 903-513-9152 mobile.

Please send approval back to our engineering group at: engcoordinators@farmerselectric.coop

Sincerely,

Griffin Trommer

Engineering Assistant

Enclosures

Submitted by:
Tricia Griffin
Field Engineering Coordinator
Office: 903-453-0563 Fax: 903-453-0663
tgriffin@farmerselectric.coop

Approved Denied

Date: 2-13-18

County Comments: with normal stipulations

14,976



FILED FOR RECORD
at 11:59 o'clock *a* M

FEB 13 2018

JENNIFER LINDENZWEIG
County Clerk, Hunt County, TX
By *J. Lindenzweig*

January 30, 2018

Office of Hunt County Judge
The Honorable John Horn
Hunt County Courthouse
2507 Lee St. Room 107
Greenville, Texas 75401

Farmers Electric Cooperative Member: Caleb Cathey
Service Order Number: 1801005846

Dear Judge Horn,

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities across Hunt County Road 2452 which is located, .25 miles northeast of Poetry Rd in Hunt County, Texas.

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossing will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact Griffin Trommer.

Sincerely,

Cody Bland

Cody Bland
Project Coordinator

cbland@farmersselectric.coop
Phone 903-455-1715 ext 4317
Mobile 903-456-1722

Submitted by Brandon Darrow
Field Engineering Coordinator

Enclosures