

FEB 13 2018

Sentingen Lindenzweig

By Cognity Fork Finit County, 70

January 15, 2018

Office of Hunt County Judge The Honorable John Horn Hunt County Courthouse 2507 Lee St. Room 107 Greenville, Texas 75401

> Farmers Electric Cooperative Member: Richard Sampson Service Order Number: 1712005649

Dear Judge Horn,

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities across <u>Hunt County Road 3131</u> which is located, 1.2 miles north of Hwy 69 in Hunt County, Texas.

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossing will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact Griffin Trommer.

Sincerely,

Tamara Williams

Tamara Williams
Project Coordinator

twilliams@farmerselectric.coop Phone 903-455-1715 ext 4049 Mobile 903-513-2903

Submitted by Brandon Darrow Field Engineering Coordinator


Enclosures

#14,977



301 N. Hillcrest Sulphur Springs, TX 75482

A Touchstone Energy Cooperative 2000 I-30 E Greenville, TX 75402



January 22, 2018

Office of Hunt County Judge The Honorable John Horn **Hunt County Courthouse** 2507 Lee St Room 107 Greenville, TX 75401

Farmers Electric Cooperative Member: Guadalupe Tamez Service Order Number: 1712005645

Dear Judge Wood,

Farmers Electric Cooperative, Inc. is requesting permission to re-route existing electrical power distribution facilities across County Road 3613, which is located approximately 391 feet west of Sabine Dr located in Hunt County.

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossing will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact your field engineering representative Griffin Trommer at 903-513-9152 mobile.

Please send approval back to our engineering group at: engcoordinators@farme	rselectric.coop
Sincerely,	
Griffin Trommer Engineering Assistant	·
Enclosures	

Submitted by: Tricia Griffin Field Engineering Coordinator Office: 903-453-0563 Fax: 903-453-0663

tgriffin@farmerselectric.coop

Approved	Denied		Date: 2-13-18	
County Comments:_	with	normal	Stipulations	