**State of Texas** 

8

8

**County of Hunt** 

JENNIFER LINDENZWEIG

## RESOLUTION NO. #14 271

## **RESOLUTION AND ORDER OF THE COMMISSIONERS COURT OF HUNT COUNTY, TEXAS** FOR DECOMMISSION OF THE HUNT COUNTY JAIL ANNEX

WHEREAS, pursuant to Texas Local Government Code 292.001 the commissioners court of a county may purchase, construct or provide by other means auxiliary county jail facilities if the commissioners court determines that the additional building or rooms are necessary; and

WHEREAS, the Hunt County Commissioners Court previously made such determination with respect to the Hunt County Jail Annex located at the intersection of Crockett St. and Stuart St. in Greenville, Hunt County, Texas (the "Jail Annex"); and

WHEREAS, the Jail Annex was previously used to house inmates, but is no longer used for such purpose; and

WHEREAS, the Hunt County Commissioners desire to decommission the use of the Jail Annex to house inmates;

NOW THREFORE BE IT RESOLVED AND ORDERED, that the Hunt County Jail Annex is hereby decommissioned from housing inmates and shall remain so decommissioned unless or until recommissioned for such purposes by resolution and order of the Commissioners Court.

IN WITNESS WHREOF, the undersigned, being the County Judge and Commissioners of Hunt County, Texas, hereby approve, consent to and adopt the above resolutions as of the 1 day of August 2020.

Bobby W. Stovall, County Judge

Eric Evans, Precinct 1

Phillip Martin, Precinct 3

Randy Strait, Precinct 2

Steve Harrison, Precinct 4

Stev Jennifer Lindenzweig, County Clerk Attest:



Randy Meeks, Sheriff Hunt County Sheriff's Office 2801 Stuart Street Greenville, TX 75401 (903) 453-6800 Main (903) 453-6832 Fax



## MEMORANDUM

DATE: August 3, 2020

TO: Bobby Stovall, County Judge

FROM: Buddy Oxford, Chief Deputy 3522

SUBJECT: Jail Annex building

The Sheriff's Office has operated the Jail Annex designated as 2403 Crockett Street for a number of years. The building has been included in the Jail Inspections performed by the Texas Jail Commission.

The building was not in compliance during the previous Jail Inspection. The generator failed to meet the jail standard. The generator will not be repaired or replaced.

Currently the building cannot be used to house inmates.

It is requested the Commissioners Court pass a resolution to close the structure from being an annex of the jail.