

19,171



Oncor Electric Delivery
Jason Conover
Associate Designer
3873 Hwy 69N
Greenville, TX 75401

November 12, 2024

Office of County Commissioners
PO Box 1097 Greenville, TX 75403

FILED FOR RECORD
at 1:00 o'clock P M

NOV 12 2024

RE: Pole Installation CR 1071, Greenville WO 26604046

BECKY LANDRUM
County Clerk, Hunt County, Tex.
By 

Greetings,

Oncor Electric Delivery LLC., is requesting permission to do work within the county right of way along CR 1071 in Greenville, 514' East of the intersection of CR 1073 and CR 1071 (For 1838 Green Meadows). We are looking to install a Pole approximately 1' inside the Southern ROW of CR 1071. Site location map and permit exhibit are enclosed. The permit exhibit details the proposed work. If you have any questions, please contact at any time.

Sincerely,



Jason Conover
Associate Designer

#19

ELECTRIC CONSTRUCTION PRINT

WO Number **26604046-01** Date: 2024/11/01 Description: Matt Kemp - 1838 Green Meadows, Greenville 75401
Sheet **1** of Scale 1"=10' Customer
Job Status Design Svc Ctr / Office CEL/ Address: 1838 green meadows , Greenville Tx 75401 GREENVILLE
Designer **COMOVER, STEVEN J/UBX** 903-458-0725 Location
Project Mgr: **COMOVER, STEVEN J/** 903-458-0725

Copyright 2008 Clear Electric Delivery. Plans, drawings, and electronic data (hereinafter) are created for the internal purposes of Clear Electric Delivery with no intention of liability or fitness for the intended use of the recipient. Clear Electric Delivery will make good faith efforts to provide products that are free from error, but does not warrant the accuracy or quality of such products. The licensee agrees not to duplicate or distribute the products or any portion of the plan set to third parties without the prior written permission of Clear Electric Delivery. The recipient further agrees to hold Clear Electric Delivery harmless against all claims, costs, expenses and damages resulting from or produced upon plan set supply for personal injuries, death or or property damage, on account of any defect in the property provided hereunder.



**2 ACSR (Phase ABC)
(24.9)
CLSTE2101**

3319248
-09617273
I: FC 100A (1)
I: 2 IN
I: 40'3 WP
I: PR 2" PVC
I: FC 100A (2)

970449
Ⓟ 20

CR1071

*Install (1) 40'3 Pole
1' inside Southern ROW
of CR1071*

3319242
-09617259

970491
Ⓟ 20

**UPD: 416825
Primary Fuse
FLN: 1857083 - 6698528**

I: 25 KVA
I: PAD (3)

I: 25 A
1838

3319189
-09617249

