



2000 I-30 E
Greenville, TX 75402

FILED FOR RECORD
at 12:00 o'clock P M

JAN 14 2025

BECKY LANDRUM
County Clerk, Hunt County, Tex.
By 

Friday, December 27, 2024

County: Hunt County

Farmers Electric Cooperative Member: Courtney Crumpton
Service Order Number: 2024124617

Greetings:

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities which will cross County Road 2200 at pole 094841 which is 815' E of CR 2206.

Site location map/construction sketches are attached. The construction sketch details the proposed work. The proposed electrical service will be constructed:

- Overhead - All road crossings will have a minimum vertical clearance of 22 feet.
- Underground - All underground bore crossings are PVC encased 4' of coverage from the lowest point of the Right of Way.

If you have any questions, please contact me at any time.

Sincerely,

Psalm Harper
pharper@farmerselectric.coop
Engineering Coordinator

Enclosures

County Approval Section:

Approved: _____ Denied: _____

Authorized Signature: _____ Date: _____

CALL MBR COURTNEY
254-291-7039 FOR GATE/
FENCE MOVED

PROTECTIVE DEVICE 65A
FUSE ON POLE 192028

PI. -96.1168 Y.33.0377

PLANNED
HOME

2 TPX

FUTURE DRIVEWAY

200

1/0 ACSR

R 2200

4 ACSR

GATES

DRIVEWAY

150ft

