


19,830



2000 I-30 E
Greenville, TX 75402



Monday, December 1, 2025

County: Hunt County

Farmers Electric Cooperative Member: Juan Salazar
Service Order Number: 2025035497

Greetings:

*Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities which will cross County Road 3133 AT POLE 103722... **CURRENT CROSSING WILL BE SHIFTING SLIGHTLY TO THE EAST AS WE ARE REPLACING THE POLE AND MOVING IT 5 FEET EAST.***

Site location map/construction sketches are attached. The construction sketch details the proposed work. The proposed electrical service will be constructed:

- Overhead - All road crossings will have a minimum vertical clearance of 22 feet.
- Underground - All underground bore crossings are PVC encased 4' of coverage from the lowest point of the Right of Way.

If you have any questions, please contact me at any time.

Sincerely,


Psalm Harper
pharper@farmerselectric.coop
Engineering Coordinator

Enclosures

County Approval Section:

Approved: _____ Denied: _____

Authorized Signature: _____ Date: _____



16

15

13r

13

14

6R

17

17R

11

10

9

8

7

2

1