

Brittany Gibson

20257

FILED FOR RECORD at <u>1:00</u> o'clock <u>9</u> M
AUG 11 2026 BECKY LANDRUM County Clerk, Hunt County, Tex. by 

From: Diana Andrade <dandrade@dunaway.com>
Sent: Wednesday, July 22, 2026 4:02 PM
To: Brittany Gibson
Cc: Tanner Underwood
Subject: ROW Permit Request - CR 3515 & CR 3552
Attachments: CR 3515 COUNTY BORE - 12-INCH TRANSMISSION WATERLINE IMPROVEMENTS.pdf;
CR 3552 COUNTY BORE - 12-INCH TRANSMISSION WATERLINE IMPROVEMENTS.pdf;
NORTH CR 3515 COUNTY BORE - 12-INCH TRANSMISSION WATERLINE
IMPROVEMENTS.pdf; TCP (1-1) - 18.pdf

Caution! This message was sent from outside your organization.

Hi Brittany,


We are currently working on a 12-inch waterline crossing County Roads 3515 and 3552 on behalf of Cash Special Utility District. I spoke with Gale and Amanda this morning and they directed me to email you the plans to begin the process of requesting a permit to bore underneath the county roads shown in the attached plans (please note that we cross CR 3515 twice). I have also included a Traffic Control Plan for your reference.

Please let me know if you require more information.

Thank you,
Diana Andrade, EIT
Graduate Engineer



T 214.234.9022
dunaway.com



STA 8+00 MATCH LINE

WARNING TO CONTRACTOR
CALL 2.00' (LOCATING SERVICE) ON OTHER UTILITY
LOCATING SERVICE 48 HOURS PRIOR TO CONSTRUCTION
ACTIVITY. EXISTING UTILITY DATA IS PROVIDED FOR
INFORMATION ONLY. AROUND THE DATA IS SHOWN AS
ACCURATELY AS POSSIBLE. THE CONTRACTOR IS CAUTIONED
THAT DUNAWAY ASSOCIATES L.P. DOES NOT ASSUME OR
BURY ANY RESPONSIBILITY FOR THE ACCURACY OF THIS
DATA.

UTILITY NOTES:
THE EXISTING UTILITIES SHOWN ON THE PLANS WERE
OBTAINED FROM VARIOUS SOURCES AND ARE INTENDED TO
SHOW THE GENERAL EXTENT AND LOCATION OF UTILITIES
IN THE AREA OF CONSTRUCTION. THE ENGINEER ASSUMES
NO RESPONSIBILITY FOR THE ACCURACY OF THE UTILITY
INFORMATION SHOWN ON THE PLANS. THE CONTRACTOR
SHALL VERIFY THE EXACT LOCATION OF ALL EXISTING
UTILITIES AND DETERMINE IF THERE ARE ANY CONFLICTS
WITH THE PROPOSED FACILITIES. THE CONTRACTOR SHALL
NOTIFY THE ENGINEER IMMEDIATELY WHEN CONFLICTS WITH
EXISTING UTILITIES ARE DISCOVERED.




PROPOSED WATER LEGEND

	PROPOSED WATER LINE
	PROPOSED BORE WITHOUT CASING
	PROPOSED BORE W/ CASING PIPE
	PROPOSED WATER VALVE
	PROPOSED REDUCER



- NOTES:**
- EXISTING WATER SERVICE ANTICIPATED WITHIN PROPOSED EASEMENT. CONTRACTOR SHALL LOCATE WATER SERVICE AND CAREFULLY EXCAVATE NEAR SERVICE LOCATIONS TO AVOID SERVICE DISRUPTIONS.
 - PROPERTIES MUST BE RETURNED TO EQUAL OR BETTER CONDITIONS.
 - CONTRACTOR SHALL REMOVE AND RESET EXISTING FENCE LINES AS NECESSARY TO A EQUAL OR BETTER CONDITION.



PRELIMINARY
FOR REVIEW ONLY
THESE DOCUMENTS ARE FOR
CONSTRUCTION AND NOT
INTENDED FOR
CONSTRUCTION, BIDDING OR
FORWARD PURPOSES. THEY
WERE PREPARED BY, OR
UNDER THE SUPERVISION OF,
JONATHAN F. UNDERWOOD
P.E. 148042
DATE: July 19, 2024


NO.	DATE	DESCRIPTION

DUNAWAY
118 MacDermott St. • P.O. Box 606 • Farmersville, Texas 75442
Tel. 972.784.7777
(FAX) 972.784.1114

BEGINNING TO STA 8+00


FM 2947 12-INCH TRANSMISSION
WATERLINE IMPROVEMENTS
TO SERVE
CASH SPECIAL UTILITY DISTRICT
HUNT COUNTY, TEXAS

JOB NO.	801.3854.004
DRAWN BY:	DAE
DESIGNED BY:	JTU
CHECKED BY:	JD
DATE:	July 28
SHEET:	6




THIS DRAWING IS THE PROPERTY OF DUNAWAY ASSOCIATES L.P. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREON. IT IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF DUNAWAY ASSOCIATES L.P.

THIS DRAWING IS THE PROPERTY OF DUNAWAY ENGINEERING, INC. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF DUNAWAY ENGINEERING, INC.



WARNING TO CONTRACTOR
CALL LOCATE BY LOCATING SERVICES OR OTHER UTILITY
LOCATING SERVICES ARE REQUIRED PRIOR TO CONSTRUCTION
ACTIVITY. EXISTING UTILITY DATA IS PROVIDED FOR
INFORMATION ONLY. ALTHOUGH THIS DATA IS SHOWN AS
ACCURATELY AS POSSIBLE, THE CONTRACTOR IS CAUTIONED
THAT DUNAWAY ASSOCIATES, L.P. DOES NOT GUARANTEE OR
WARRANT ANY RESPONSIBILITY FOR THE ACCURACY OF THIS
DATA.

UTILITY NOTES
THE EXISTING UTILITIES SHOWN ON THE PLANS WERE
OBTAINED FROM VARIOUS SOURCES AND ARE INTENDED TO
SHOW THE GENERAL EXISTENCE AND LOCATION OF UTILITIES
IN THE AREA OF CONSTRUCTION. THE CONTRACTOR ASSUMES
NO RESPONSIBILITY FOR THE ACCURACY OF THE UTILITY
INFORMATION SHOWN ON THE PLANS. THE CONTRACTOR
SHALL VERIFY THE EXACT LOCATION OF ALL EXISTING
UTILITIES AND DETERMINE IF THERE ARE ANY CONFLICTS
WITH THE PROPOSED FACILITIES. THE CONTRACTOR SHALL
NOTIFY THE ENGINEER IMMEDIATELY WHEN CONFLICTS WITH
EXISTING UTILITIES ARE DISCOVERED.



- NOTES:
1. PARCEL 9 - JUDSON FOSS & CHERYL
FOSS TRACT INSET LINE IN TREES TO
PRESERVE TREE LINE ON FENCELINE. AVOID
ENTRY GATE ON BORE, BORE CROSSFENCE
WITH TREES. ONLY STAGE EQUIPMENT IN
PARCEL IF WORKING ON PARCEL. ANY
FUTURE REPAIRS, PROPERTY MUST BE
RETURNED TO ORIGINAL CONDITIONS.
 2. EXISTING WATER SERVICE ANTICIPATED
WITHIN PROPOSED EASEMENT. CONTRACTOR
SHALL LOCATE WATER SERVICE AND
CAREFULLY EXCAVATE NEAR SERVICE
LOCATIONS TO AVOID SERVICE DISRUPTIONS.
 3. PROPERTIES MUST BE RETURNED TO
EQUAL OR BETTER CONDITIONS.
 4. CONTRACTOR SHALL REMOVE AND RESET
EXISTING FENCE LINES AS NECESSARY TO A
EQUAL OR BETTER CONDITION.

PRELIMINARY
FOR REVIEW ONLY
THESE DOCUMENTS ARE FOR
DESIGN REVIEW AND NOT
INTENDED FOR
CONSTRUCTION. BIDDING OR
FOR ANY PURPOSES, THEY
WERE PREPARED BY, OR
UNDER THE SUPERVISION OF,
JOHNATHAN T. LUNDSTROM
P.E. 148042
DATE: July 19, 2024

REVISIONS	
NO.	DESCRIPTION

DUNAWAY
118 McDermott St. • P.O. Box 684 • Farmington, Texas 75442
(254) 824-1114




STA 24+00 TO STA 32+00
**FM 2947 12-INCH TRANSMISSION
WATERLINE IMPROVEMENTS
TO SERVE
CASH SPECIAL UTILITY DISTRICT
HUNT COUNTY, TEXAS**

JOB NO.	8013854.004
DRAWN BY:	DAA
DESIGNED BY:	JTU
CHECKED BY:	JD
DATE:	July 18

SHEET:
9

DISCLAIMER: This standard is governed by the "Texas Engineering Practice Act". No warranty of any kind is made by TxDOT for any purpose whatsoever. TxDOT assumes no responsibility for the conversion of this standard to other formats or for incorrect results or damages resulting from its use.

DATE: FILE:



LEGEND			
	Type 3 Barricade		Channelizing Devices
	Heavy Work Vehicle		Truck Mounted Attenuator (TMA)
	Trailer Mounted Flashing Arrow Board		Portable Changeable Message Sign (PCMS)
	Sign		Traffic Flow
	Flag		Flagger

Posted Speed X	Formula	Minimum Desirable Taper Lengths ft			Suggested Maximum Spacing of Channelizing Devices		Minimum Sign Spacing ft	Suggested Longitudinal Buffer Spacing ft
		10' Offset	11' Offset	12' Offset	On a Taper	On a Tangent	Distance	ft
30	$L = \frac{WS^2}{60}$	150'	165'	180'	30'	60'	120'	90'
35		205'	225'	245'	35'	70'	160'	120'
40		265'	295'	320'	40'	80'	240'	155'
45		450'	495'	540'	45'	90'	320'	195'
50		500'	550'	600'	50'	100'	400'	240'
55	$L = WS$	550'	605'	660'	55'	110'	500'	295'
60		600'	660'	720'	60'	120'	600'	350'
65		650'	715'	780'	65'	130'	700'	410'
70		700'	770'	840'	70'	140'	800'	475'
75		750'	825'	900'	75'	150'	900'	540'

* Conventional Roads Only
XX Taper lengths have been rounded off.
L=Length of Taper (FT) W=Width of Offset (FT) S=Posted Speed (MPH)

TYPICAL USAGE				
MOBILE	SHORT DURATION	SHORT TERM STATIONARY	INTERMEDIATE TERM STATIONARY	LONG TERM STATIONARY
	✓	✓		



- GENERAL NOTES**
- Flags attached to signs where shown are REQUIRED.
 - All traffic control devices illustrated are REQUIRED, except those denoted with the triangle symbol may be omitted when stored elsewhere in the plans, or for routine maintenance work, when approved by the Engineer.
 - Inactive work vehicles or other equipment should be parked near the right-of-way line and not parked on the paved shoulder.
 - A Shadow Vehicle with a TMA should be used anytime it can be positioned 30 to 100 feet in advance of the area of crew exposure without adversely affecting the performance or quality of the work. If workers are no longer present but road or work conditions require the traffic control to remain in place, Type 3 Barricades or other channelizing devices may be substituted for the Shadow Vehicle and TMA.
 - Additional Shadow Vehicles with TMAs may be positioned off the paved surface, next to those shown in order to protect wider work spaces.
 - See TCP (5-1) for shoulder work on divided highways, expressways and freeways.
 - CB21-5 "SHOULDER WORK" signs may be used in place of CW20-10 "ROAD WORK AHEAD" signs for shoulder work on conventional roadways.

Texas Department of Transportation **Traffic Operations Division Standard**

TRAFFIC CONTROL PLAN
CONVENTIONAL ROAD
SHOULDER WORK

TCP (1-1)-18

FILE: top1-1-18.dgn	DATE: December 1985	DESIGN: JWB	CHECK: JWB	DATE: 1-18-86
REVISIONS		SHEET NO.		
2-84 4-86	9-85 2-12	1-87 2-18		



WARNING TO CONTRACTOR
CALL TEXAS 811 (LOCATING SERVICE) OR OTHER UTILITY
LOCATING SERVICES 48 HOURS PRIOR TO CONSTRUCTION
ACTIVITY. EXISTING UTILITY DATA IS PROVIDED FOR
INFORMATION ONLY. ALTHOUGH THIS DATA IS SHOWN AS
ACCURATE AS POSSIBLE, THE CONTRACTOR IS CAUTIONED
THAT DUNHAM ASSOCIATES, L.P. DOES NOT ASSUME
ANY RESPONSIBILITY FOR THE ACCURACY OF THIS
DATA.

THE EXISTING UTILITIES SHOWN ON THE PLANS WERE COMPILED FROM VARIOUS SOURCES AND ARE REFERRED TO AS GENERAL EXISTENCE AND LOCATION OF UTILITIES. IN THE AREA OF CONSTRUCTION THE ENGINEER ASSUMES NO RESPONSIBILITY FOR THE ACCURACY OF THE UTILITIES INFORMATION SHOWN ON THE PLANS. THE CONTRACTOR SHALL VERIFY THE EXISTENCE AND LOCATION OF UTILITIES PRIOR TO ANY CONSTRUCTION ACTIVITY. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION OF ALL EXISTING UTILITIES AND DETERMINE THERE ARE ANY CONFLICTS WITH PROPOSED CONSTRUCTION. THE CONTRACTOR SHALL NOTIFY THE ENGINEER IMMEDIATELY WHEN CONFLICTS WITH EXISTING UTILITIES ARE DISCOVERED.



PROPOSED WATER LEGEND

-  PROPOSED WATER LINE
 PROPOSED BORE WITHOUT CASING
 PROPOSED BORE W/ CASING PIPE
 PROPOSED WATER VALVE
 PROPOSED REDUCER



NOTES:

- NOTES:
1. EXISTING LOT 9 - JUDSON Foss & Cheryl Foss TRACT INSET LINE IN TREES TO PRESERVE TREE LINE ON FENCELINE. AVOID ENTRY GATE ON BORE, BORE CROSSFENCE MUST BE MAINTAINED TO PREVENT ENTRY ON PARCEL IF WORKING ON PARCEL. ANY FUTURE REPAIRS, PROPERTY MUST BE RETURNED TO ORIGINAL CONDITIONS.
2. EXISTING WATER SERVICE ANTICIPATED WITHIN PROPOSED EASEMENT. CONTRACTOR MUST LOCATE AND MARK SERVICE. CAREFULLY EXCAVATE NEAR SERVICE LOCATIONS TO AVOID SERVICE DISRUPTIONS.
3. PROPERTIES MUST BE RETURNED TO EQUAL OR BETTER CONDITIONS.
4. CONTRACTOR SHALL REMOVE AND RESET EXISTING DRIVE LINE AS NECESSARY TO A EQUAL OR BETTER CONDITION.

[illegible]

STA 24+00 TO STA 32+00


FM 2947 12-INCH TRANSMISSION
WATERLINE IMPROVEMENTS
TO SERVE
CASH SPECIAL UTILITY DISTRICT
HUNT COUNTY, TEXAS

JOB NO.	8013854.004
DRAWN BY:	DAA
DESIGNED BY:	JTU
CHECKED BY:	ZD
DATE:	July 26
SHEET:	

SHEET: 9

STA 200+00 MATCH LINE

STA 208+00 MATCH LINE



WARNING TO CONTRACTOR
CALL TOWNS BY LOCATING SERVICE OR OTHER UTILITY LOCATING SERVICE 48 HOURS PRIOR TO CONSTRUCTION ACTIVITY. EXISTING UTILITY DATA IS PROVIDED FOR INFORMATION ONLY. ALTHOUGH THIS DATA IS SHOWN AS ACCURATELY AS POSSIBLE, THE CONTRACTOR IS CAUTIONED THAT DUNAWAY ASSOCIATES L.P. DOES NOT ASSUME OR Warrant ANY RESPONSIBILITY FOR THE ACCURACY OF THIS DATA.

UTILITY NOTES:
THE EXISTING UTILITIES SHOWN ON THE PLANS WERE COMPILED FROM VARIOUS SOURCES AND ARE INTENDED TO SHOW THE GENERAL EXISTENCE AND LOCATION OF UTILITIES IN THE AREA OF CONSTRUCTION. THE CONTRACTOR ASSUMES NO RESPONSIBILITY FOR THE ACCURACY OF THE UTILITY INFORMATION SHOWN ON THE PLANS. THE CONTRACTOR SHALL CONTACT A UTILITY LOCATING SERVICE 48 HOURS PRIOR TO ANY CONSTRUCTION ACTIVITY. THE CONTRACTOR SHALL NOTIFY THE EXACT LOCATION OF ALL EXISTING UTILITIES AND OBTAIN PERMISSION FROM THE UTILITY OWNERS WITH THE PROPOSED FACILITIES. THE CONTRACTOR SHALL NOTIFY THE UTILITY OWNERS IMMEDIATELY WHEN CONFLICTS WITH EXISTING UTILITIES ARE DISCOVERED.



PROPOSED WATER LEGEND

	PROPOSED WATER LINE
	PROPOSED BORE WITHOUT CASING
	PROPOSED BORE W/ CASING PIPE
	PROPOSED WATER VALVE
	PROPOSED REDUCER



- NOTES:**
- EXISTING WATER SERVICE ANTICIPATED WITHIN PROPOSED EASEMENT. CONTRACTOR SHALL LOCATE WATER SERVICE AND CAREFULLY EXCAVATE NEAR SERVICE LOCATIONS TO AVOID SERVICE DISRUPTIONS.
 - PROPERTIES MUST BE RETURNED TO EQUAL OR BETTER CONDITIONS.
 - CONTRACTOR SHALL REMOVE AND RESET EXISTING FENCE LINES AS NECESSARY TO A EQUAL OR BETTER CONDITION.
 - ELIZABETH KAY MOORE PARCEL BE AWARE OF LATERAL LINE'S NORTH SIDE OF THE PROPERTY.


REVISIONS	
NO.	DATE

DUNAWAY
118 McKinney St. • P.O. Box 604 • Fort Worth, Texas 76144
Tel: 817.724.7777
(FEDERAL HIGHWAY 1114)



STA 200+00 TO STA 208+00

FM 2947 12-INCH TRANSMISSION WATERLINE IMPROVEMENTS TO SERVE CASH SPECIAL UTILITY DISTRICT HUNT COUNTY, TEXAS

JOB NO.	8013854 004
DRAWN BY:	DMA
DESIGNED BY:	ITU
CHECKED BY:	JD
DATE:	July 28
SHEET:	31




PRELIMINARY FOR REVIEW ONLY. THESE DOCUMENTS ARE FOR DESIGN REVIEW AND NOT INTENDED FOR CONSTRUCTION, BIDDING OR PERMIT PURPOSES. THEY WERE PREPARED BY OR UNDER THE SUPERVISION OF JONATHAN T. UNDERWOOD P.E. (18043) DATE: July 9, 2006




WARNING TO CONTRACTOR
CALL TENS BY LOCATING SERVICE, OR OTHER UTILITY LOCATING SERVICE, OR HOURS FROM TO CONSTRUCTION ACTIVITY. EXISTING UTILITY DATA IS PROVIDED FOR INFORMATION ONLY. A PROPERTY OWNER'S DATA IS PROVIDED AS ACCURATELY AS POSSIBLE. THE CONTRACTOR IS CAUTIONED THAT DUNAWAY ASSOCIATES, L.P. DOES NOT ASSUME OR BEAR ANY RESPONSIBILITY FOR THE ACCURACY OF THIS DATA.

UTILITY NOTES
THE EXISTING UTILITIES SHOWN ON THE PLANS WERE OBTAINED FROM VARIOUS SOURCES AND ARE INTENDED TO SHOW THE GENERAL EXISTENCE AND LOCATION OF UTILITIES. IN THE AREA OF CONSTRUCTION THE CONTRACTOR ASSUMES NO RESPONSIBILITY FOR THE ACCURACY OF THE UTILITY INFORMATION SHOWN ON THE PLANS. THE CONTRACTOR SHALL CONTACT A UTILITY LOCATING SERVICE AS HOURS FROM TO ANY CONSTRUCTION ACTIVITY. THE CONTRACTOR SHALL VERIFY THE EXACT LOCATION OF ALL EXISTING UTILITIES AND DETERMINE IF THERE ARE ANY CONFLICTS WITH THE PROPOSED FACILITIES. THE CONTRACTOR SHALL NOTIFY THE OWNER IMMEDIATELY IN WRITING IF ANY CONFLICTS WITH EXISTING UTILITIES ARE DISCOVERED.



- NOTES:**
1. EXISTING WATER SERVICE ANTICIPATED WITHIN PROPOSED EASEMENT. CONTRACTOR SHALL LOCATE WATER SERVICE AND CAREFULLY EXCAVATE NEAR SERVICE LOCATIONS TO AVOID SERVICE DISRUPTIONS.
 2. PROPERTIES MUST BE RETURNED TO EQUAL OR BETTER CONDITIONS.
 3. CONTRACTOR SHALL REMOVE AND RESET EXISTING FENCE LINES AS NECESSARY TO A EQUAL OR BETTER CONDITION.



REVISIONS		DESCRIPTION	
NO.	DATE		

118 McCrory St. • P.O. Box 606 • Fort Worth, Texas 76142
(817) 778-7777
(FAX) (817) 778-7777

BEGINNING TO STA 8+00

FM 2947 12-INCH TRANSMISSION WATERLINE IMPROVEMENTS TO SERVE CASH SPECIAL UTILITY DISTRICT

MONTGOMERY COUNTY, TEXAS

JOB NO.	8013854-004
DRAWN BY:	ONE
DESIGNED BY:	ONE
CHECKED BY:	ONE
DATE:	July 26
SHEET:	6